


# Checklist Annual retesting



# Checklist

## Annual retesting

Test:		Examiner:		Date:		<b>JK International GmbH</b> Division JK Global Service  Köhlershohner Straße 60 53578 Windhagen Tel.: +49 (0) 2224 / 818-861 Fax: +49 (0) 2224 / 9735-205					
Customer:				Model:							
Street:				Device number:							
Post code and city/town				Year of commissioning:							
Studio:		Cabin:		Hours of operation:							
Component/wear part	Test interval	extended test +	Replacement interval	Type of test	Instructions	Results					
						OK. 1)	Not OK .2)	N/A.3)	new	Remarks	
<b>Electrical connections</b>											
Plug-in connector (HSU, AMP, Harting, etc.)	5 years	N/A	Replace as required	In accordance with instructions	1.1						
Plug (CEE connection terminal)	1 year	N/A	Replace as required	In accordance with instructions	1.2						
Connection terminals	1 year	N/A	Replace as required	In accordance with instructions	1.3						
Internal terminals (spring-loaded)	10 years	N/A	Replace as required	In accordance with instructions	1.4						
Internal terminals (screw-type terminals)	10 years	N/A	Replace as required	In accordance with instructions	1.5						
Cable bushings	1 year	10 years	Replace as required	In accordance with instructions	1.6						
Electrical wiring/cable	10 years	N/A	Replace as required	In accordance with instructions	1.7						
<b>Electrical components</b>											
Electrolytic capacitors	5 years	N/A	Replace as required	<b>Measure power consumption All 3 phases</b>	2.1						
Interference suppressor filters	1 year	N/A	Replace as required	In accordance with instructions	2.2						
PCBs	1 year	10 years	Replace as required	In accordance with instructions	2.3						
Relay/contactors	1 year	N/A	Replace as required	In accordance with instructions	2.4						
Skin sensor	1 year	N/A	Replace as required	In accordance with instructions	2.5						
Power supply units, switching power supply units	1 year	N/A	Replace as required	In accordance with instructions	2.6						
Audio	1 year	N/A	Replace as required	In accordance with instructions	2.7						

\*The next extended check must be carried out in the 15th year  
 1) Pass 2) Fail 3) Not applicabl

# Checklist

## Annual retesting

Component/wear part	Test interval	extended test*	Replacement interval	Type of test	Instructions	Results				
						OK. 1)	Not OK .2)	N/A.3)	new	Remarks
<b>Aqua Fresh</b>										
AF compressor	1 year	N/A	Replace as required	In accordance with instructions	3.1					
AF valves/aroma	1 year	N/A	Replace as required	In accordance with instructions	3.2					
AF pumps	1 year	N/A	Replace as required	In accordance with instructions	3.3					
Nozzle AF/aroma hoses	N/A	10 years	Replace as required	In accordance with instructions	3.4					
AquaFresh liquid	See operating instructions		Replace as required	Visual test	3.5					
Aroma liquid	See operating instructions		Replace as required	Visual test	3.6					
<b>Air conditioner</b>										
Condensation pump	1 year	N/A	Replace as required	In accordance with instructions	4.1					
Float switch	1 year	N/A	Replace as required	In accordance with instructions	4.2					
Air conditioning system	1 year	N/A	Replace as required	In accordance with instructions	4.3					
Air ducts	1 year	N/A	Replace as required	In accordance with instructions	4.4					
Heater	1 year	10 years	Replace as required	In accordance with instructions	4.5					
<b>Acrylic</b>										
Acrylic bed panel	1 year/ 1500 h	N/A	Replace as required	In accordance with instructions	5.1					
Acrylic panel: Canopy/side section	1 year/ 1500 h	N/A	Replace as required	In accordance with instructions	5.2					
Acrylic panel: Partition	1 year/ 3000 h	N/A	Replace as required	In accordance with instructions	5.3					
Acrylic panel: Shoulder tanner	1 year/ 3000 h	N/A	Replace as required	In accordance with instructions	5.4					
Closed tanning tunnel	1 year	N/A	Replace as required	In accordance with instructions	5.5					
Headrest	1 year	N/A	Replace as required	In accordance with instructions	5.6					
<b>Ballasts, starting devices</b>										
Conventional magnetic ballast	1 year	10 years	Replace as required	In accordance with instructions	6.1					
Electrical ballast	1 year	10 years	Replace as required	In accordance with instructions	6.2					
Starting device	1 year	N/A	Replace as required	In accordance with instructions	6.3					

\*The next extended check must be carried out in the 15th year  
 1) Pass 2) Fail 3) Not applicabl

# Checklist

## Annual retesting

Component/wear part	Test interval	extended test*	Replacement interval	Type of test	Instructions	Results				
						OK. 1)	Not OK .2)	N/A.3)	new	Remarks
<b>Exhaust air, ventilation</b>										
Exhaust flap spring	1 year	10 years	Replace as required	In accordance with instructions	7.1					
Exhaust air hose	1 year	N/A	Replace as required	In accordance with instructions	7.2					
Internal air lines	1 year	N/A	Replace as required	In accordance with instructions	7.3					
Gaiter/canopy to base	1 year	10 years	Replace as required	In accordance with instructions	7.4					
EPP air ducts	1 year	N/A	Replace as required	In accordance with instructions	7.5					
EPP control boxes	1 year/ 2000 h	N/A	Replace as required	In accordance with instructions	7.6					
Fan	1 year	N/A	Replace as required	In accordance with instructions	7.7					
Servo motors	1 year	10 years	Replace as required	In accordance with instructions	7.8					
Air filter	1 year	N/A	Replace as required	In accordance with instructions	7.9					
<b>Bearings, springs, shock absorbers</b>										
Springs	1 year/ 2000 h	N/A	10 years/ 20000 h	In accordance with instructions	8.1					
Bearings/sliding bearings	1 year/ 2000 h	N/A	10 years/ 20000 h	In accordance with instructions	8.2					
Rubber-metal buffer (lifting mechanism and fan)	1 year/ 2000 h	N/A	10 years/ 20000 h	N/AIn accordance with instructions	8.3					
Cables and guide rollers	1 year/ 2000 h	N/A	10 years/ 20000 h	In accordance with instructions	8.4					
Fall protection	1 year/ 2000 h	N/A	10 years/ 20000 h	In accordance with instructions	8.5					
Lifting mechanism	1 year/ 2000 h	N/A	10 years/ 20000 h	In accordance with instructions	8.6					
Gas pressure absorbers/ oil dampers	1 year/ 2000 h	N/A	Replace as required	In accordance with instructions	8.7					
Transport rollers	1 year	N/A	Replace as required	In accordance with instructions	8.8					
<b>UV components</b>										
Lamps / LP / HP / LED	1 year	N/A	Replace as required	In accordance with instructions	9.1					
Filter panels	1 year	N/A	Replace as required	In accordance with instructions	9.2					
Reflectors	1 year	N/A	Replace as required	In accordance with instructions	9.3					
Starter	See operating instructions		Replace as required	In accordance with instructions	9.4					

\*The next extended check must be carried out in the 15th year

1) Pass 2) Fail 3) Not applicabl

# Checklist

## Annual retesting

Component/wear part	Test interval	extended test*	Replacement interval	Type of test	Instructions	Results				
						OK .1)	Not OK.2)	N/A.3)	new	Remarks
Chip cards	See operating instructions		Replace as required	In accordance with instructions	9.5					
Lamp sockets	1 year	N/A	Replace as required	In accordance with instructions	9.6					
Pure AIR	1 year/ 2000 h	N/A	10 years/ 10000 h	In accordance with instructions	9.7					
<b>Safety switches/locks</b>										
Sensors (temperature, pressure,	1 year	N/A	Replace as required	In accordance with instructions	10.1					
Temperature limiter	1 year	N/A	Replace as required	In accordance with instructions	10.2					
Switches/ water switches	1 year	N/A	Replace as required	In accordance with instructions	10.3					
Opening-locking mechanism	1 year	N/A	Replace as required	In accordance with instructions	10.4					
<b>Vibra</b>										
Vibration plate	1 year	10 years	Replace as required	In accordance with instructions	11.1					
Rubber mat/ silicone foot mat	1 year	10 years	Replace as required	In accordance with instructions	11.2					
<b>Operation</b>										
Handles/retaining ropes	1 year	10 years	Replace as required	In accordance with instructions	12.1					
Control films/safety mat	1 year	N/A	Replace as required	In accordance with instructions	12.2					
<b>Mechanical components</b>										
Seats	1 year/ 2000 h	N/A	Replace as required	In accordance with instructions	13.1					
Plastic panels	1 year/ 2000 h	N/A	Replace as required	In accordance with instructions	13.2					
Protective grille against intervention	1 year	N/A	Replace as required	In accordance with instructions	13.3					
Warning label	1 year/ 2000 h	N/A	Replace as required	In accordance with instructions	13.4					
<b>Pure AIR air hygiene</b>										
Clean fan	1 year	N/A	Replace as required	In accordance with instructions	14.1					
Clean Lightblock/Tubelock	1 year	N/A	Replace as required	In accordance with instructions	14.2					
Clean filter mats and protective grille	1 year	N/A	Replace as required	In accordance with instructions	14.3					
Replacing the UV-C lamps	1 year	N/A	9000 h	In accordance with instructions	14.4					

\*The next extended check must be carried out in the 15th year

1) Pass 2) Fail 3) Not applicabl

# Checklist

## Annual retesting

Component/wear part	Test interval	extended test*	Replacement interval	Type of test	Instructions	Results				
						OK .1)	Not OK.2)	N/A.3)	new	Remarks
Replacing the reflector	1 year	N/A	Replace as required	In accordance with instructions	14.5					
Electrical test	1 year	N/A	Replace as required	In accordance with instructions	14.6					

Measurement in accordance with DIN EN 50678(VDE 0701) / DIN EN 50699(VDE 0702)				
			Limit	Actual
Protective earth conductor	RSL		< 0.3 Ohms	<b>Ohm</b>
Insulation measurement	RISO		> 1 M Ohms	<b>M Ohm</b>
Protective earth conductor measurement *			< 3.5 mA	<b>m A</b>
High voltage measurement	U <sub>HV</sub>		1 kV	<b>kV</b>
Touch current *1			< 0.5 mA	<b>mA</b>
Test of function				
<b>Performed</b>			<b>Not performed</b>	

\*No equivalent leakage current measurement permitted

\*1 Only for conductive, touchable parts not connected to PE

Date :

Signature of technician :

\*The next extended check must be carried out in the 15th year

1) Pass 2) Fail 3) Not applicabl